

LENOIR - ELEC

OVER VOLTAGE PROTECTOR

**MAINTENANCE
INSTRUCTIONS**
MA1010/01
02/02


MOUNTING PRECAUTIONS

- Set the overvoltage protector in the vertical position (cover towards the top).
- Caution to respect polarized busbars for PSPL type.
- After installation, check the triggering threshold with a voltage generator at 15 A.


Number marks of the connector's pins

electrical diagram following auxiliary contact type.

one auxiliary contact
CROUZET type



two auxiliary contacts
MILTAC type



LENOIR - ELEC

Z.I de la Castine - Rue des Sapins
54730 GORCY (FRANCE)
Tél : 33 (0)3 82 23 79 89 Fax : 33 (0)3 82 23 84 30
E-mail : lenoir@lenoir-elec.com