

LENOIR - ELEC


MECHANICAL LOCKING
for bar contactors type
80 to 4000A

**MAINTENANCE
INSTRUCTIONS**
M24104A/16
02/02

BE CAREFUL

When one of the contactors closes, the track rod of the mechanical locking always must be tightened.
It is the same in case of locking for different size devices.


SIZES 80 TO 200



LENOIR - ELEC


Z.I de la Castine - Rue des Sapins
54730 GORCY (FRANCE)
Tél : 33 (0)3 82 23 79 89 Fax : 33 (0)3 82 23 84 30
E-mail : lenoir@lenoir-elec.com

SIZES 400 TO 1000



- put attachments (A) on shafts (B)
- assemble the track rod (C)
- adjust it to obtain :
 - * the same length of 10 mm from each side.
 - * a 0.5 mm gap between stud (F) and the bottom of (G) on the lower part, «upper» contactor is opened and «lower» contactor is closed.

SIZES 1250 TO 2000



- put attachments (A) on shafts (B)
- assemble the track rod (C)
- adjust it to obtain :
 - * the same length from each side (E).
 - * a 0.5 mm gap between stud (F) and the bottom of (G) on the lower part, «upper» contactor is opened and «lower» contactor is closed.



LENOIR - ELEC

Z.I de la Castine - Rue des Sapins
54730 GORCY (FRANCE)
Tél : 33 (0)3 82 23 79 89 Fax : 33 (0)3 82 23 84 30
E-mail : lenoir@lenoir-elec.com